



भारतीय समुद्री विश्वविद्यालय Indian Maritime University

(केन्द्रीय विश्वविद्यालय, भारत सरकार / A Central University, Govt. of India)
कोलकाता परिसर / Kolkata Campus

Subject: S.I.T.C of electrical cable, MCB etc at IMU-KC.

As per three in no pump installation at IMU-KC on urgent basis for fast water drainage during water logging periods of campus, different electrical arrangement are required which are given below.

S.I.T.C of different electrical cable , MCB etc at IMU-KC.						
SL NO	DESCRIPTION OF ITEMS	QUANTITY	Make	Base rate	Tax	Gross amount
1	Supply installation testing and commissioning (S.I.T.C) of 4 core x 10 sq mm copper armoured cable including excavation, laying ,sand Cushioning, protective covering and refilling the cable trench, terminal connection ,socketing etc as required.(road crossing about 5 metre)	80 metre (approx)				
2	Supply installation testing and commissioning (S.I.T.C) of 3 core x 10 sq mm copper armoured cable including excavation, laying, sand Cushioning, protective covering and refilling the cable trench, terminal connection, socketing etc as required.	80 metre (approx)				
3	S.I.T.C of 63 Amp FP MCB with metal sheet enclosure (water proof) with connection as required.	01 no				
4	S.I.T.C of 40 Amp tP MCB with metal sheet enclosure (water proof) with connection as required.	1 no				
5	S.I.T.C of 20 Amp DP MCB with metal sheet enclosure (water proof) with connection as required.	2 no				
6	Motor pump set (5.5 KW 7.5HP monoblock IP68 pump,3 Phase) fixing and connection through DOL starter as required. (Pump motor set, Starter available at IMU-KC)	1 no				
7	Motor pump set (2HP monoblock submarcible pump,Single Phase) fixing and connection through DOL starter as required. (Pump motor set, Starter available at IMU-KC)	02 no				

Any query kindly contact to Md. Sabir Ali (M 9681146748) , AE(Electrical), IMU Kolkata Campus

N.B.

- Final bill will be made on the basis of actual measurements and materials consumption & after completion of work.
- Time lines – 07 daysafter award letter/work order.
- Materials should be from reputed make company & superior quality. Acceptable to IMU-KC.
- Quote the rate in unit system and mentioned the makers name also.
- Quotation should be addressed to The Director, IMU-KC, Kolkata 700088, before 07-07-2017.

पि-19, तारातला रोड, कोलकाता - 700 088 / P-19, Taratala Road, Kolkata - 700 088

Email : director.kol@imu.co.in

Phone : (033) 2401 4673/74/76/78/1946, Fax : (033) 2401 4333, Hostel : 2401 4675